

COMMVAULT - 2ND FLOOR

This drawing is copyright of Curve Workplaces Limited & must not be copied or reproduced in any way without written permission.

Do not scale! If in doubt ask.



NOTES:

[add notes]

- **Revisions C3**
- Comms room and equipment sizes confirmed.
- Latest furniture layout from Forum



EXACT SETTING OUT OF IT/COMMS TO BE CONFIRMED WITH COMMVAULT IT
SOLID WALL WITH SHELVING ON BRACKETS

LOBBY DOORS FIXED TO OPENING INTO OFFICE SPACE. APPROVED BY BUILDING CONTROL on the basis that the alternative escape route is available to occupants and that the occupancy level is below 60 within this area as indicated on plan, this would be acceptable.

BUILDING CONTROL CONFIRMED FIRE ALARM FLASHING BEACON TO BE PROVIDED FOR WELLNESS ROOM

GENERAL ARRANGEMENT

Rev:	Date:	Description:
C3	26.10.2020	Comms room and furniture layout updated
C2	09.10.2020	Building Control notes added
C1	05.10.2020	Amendment to IT layout following specs
P6	29.09.2020	Furniture Forum blocks added
P5	21.09.2020	Minor amendments to suit MD feedback
P4	15.09.2020	Locker niche detail updated to line through with front face of locker
P3	11.09.2020	Partition thickness amended to 100mm and minor updates following call
P2	04.09.2020	Minor amendments to suit MD feedback
P1	31.08.20	AMENDED FOLLOWING MD COMMENTS

Document Status:

FOR INFORMATION

CURVE
The Lightbox
Willoughby Road
Bracknell
RG12 8FB
www.curveworkplaces.co.uk

Client:
COMMVAULT
1330 ARLINGTON BUSINESS PARK
READING

Drawing Title:

GENERAL ARRANGEMENT

Drawn:	SB	Checked:	
Scale:	A1 @	Date:	
Document Number:	JOB NUMBER FLOOR TYPE REVISION		
	1337	- 02	- GA C3

